



CITY OF [NAME OF CITY]
 Department of [NAME OF DEPARTMENT]
 [NAME OF DIVISION OR BUREAU]



**COMMERCIAL
 PLAN REVIEW CHECKLIST**

INFORMATION	PLAN CHECK NO.:		EXPIRATION DATE:			STATUS:	
	PROJECT ADDRESS:						
	WORK DESCRIPTION:						
	APPLICANT'S NAME:				TEL. NO.:		
	ADDRESS:				EMAIL:		
	USE	OCCUPANCY GROUP	FLOOR AREA	OCCUPANT LOAD	TYPE OF CONSTR.	NO. OF STORIES	FIRE SPRINKLER LOCATION
INSTRUCTIONS	<p>Your application for a permit, together with plans and specifications, has been examined and you are advised that the issuance of a permit is withheld for the reasons hereinafter set forth. The approval of plans and specifications does not permit the violation of any sections of the Building Code or other local ordinances or state laws.</p> <p>In an effort to streamline the plan review process, please follow the steps outlined below to ensure that there is no delay in processing your application and reviewing your responses to these plan check comments.</p> <ul style="list-style-type: none"> • Comments with circled item numbers apply to this plan check. • Revised plans and calculations shall incorporate or address all comments marked on the original checked set of plans, calculations, and this plan review checklist. Provide a written response to each comment and show where and how it has been addressed. Identify the sheet number and detail or reference note on the revised plans where the corrections are made. Time spent searching for the corrected items on the revised plans or calculations will delay the review and approval process. Once all comments on the plans, calculations, and this checklist have been addressed, contact the plan check staff to schedule an appointment to review the changes made. 						
	PLAN REVIEWER: _____ TEL. NO.: _____ ADDRESS: _____ EMAIL: _____ WEBSITE: _____						
	Should you have any questions or need clarification pertaining to the comments made on your project, you may contact the plan check staff by telephone from _____ to _____ M T W TH F.						
	<ul style="list-style-type: none"> • Bring the original checked set of plans and calculations along with this checklist to the meeting. Do not schedule an appointment meeting with the plan check staff until all comments have been addressed. • Incomplete, indefinite or faded drawings or calculations will not be accepted. 						
NOTE	Numbers within the parenthesis () refer to the section of the applicable code. 2007 California Building Code (CBC). Table (T). 2007 California Plumbing Code (CPC). 2007 California Mechanical Code (CMC). 2007 California Fire Code (CFC).						



CHAPTER 1 GENERAL PROVISIONS

A. PERMIT APPLICATION

1. Provide a fully dimensioned plot plan to scale, in ink and copy it to the plot plan sheet provided by the department. Include the following information as applicable: project address, type of construction, number of stories, use and occupancy of the building, fire separation distance or setback of building to property lines or other buildings on the lot, lot size and dimensions, street center line, alley, # of parking spaces, location of all other buildings on the lot, legal description, and permit application number.
2. Valuation provided or determined during the initial submittal process was not accurate. Valuation is revised to \$_____. Pay additional required plan check fee of \$_____.
3. Provide complete and correct legal description (i.e., Tract, Lot, Block, APN, metes and bounds, etc.).
4. Provide complete information for (applicant) (owner) (engineer) (architect) (contractor) (_____).
5. Separate permit application is required for the following items:
 - a. Retaining walls or block fence walls
 - b. Grading work
 - c. Swimming pools
 - d. Separate structures
 - e. Shoring
 - f. Demolition
 - g. Electrical, Mechanical, and/or Plumbing work
 - h. Fire sprinkler systems
 - i. Signs
 - j. Others _____
6. When all required approvals are obtained, the permit application must be signed by the property owner, licensed contractor, or authorized agent at the time the permit is to be issued:
 - a. For owner-builder permits: Owner's signature can be verified with owner's driver license. Owner's representatives must present owner's approval with a notarized letter from the owner.
 - b. For contractor building permits: Prior to the issuance of a building permit, the contractor shall have the following:
 - i. Certificate of workers Compensation Insurance made out to the Contractors State License Board.
 - ii. Copy of Contractors State License or pocket ID.

- iii. Copy of city business tax registration certificate or a newly paid receipt for one.
- iv. Notarized letter of authorization for agents.

B. ADMINISTRATION

1. Obtain all approvals/clearances from the following department/bureau/agency noted below. It is necessary to apply immediately for the signoff as it can take weeks or months for some departments/bureaus/agencies to review and approve the project. All required approvals/clearances must be secured prior to permit issuance.
2. The final set of construction documents must be stamped by the following department/bureau/agency:
 - a. Planning
 - b. Fire
 - c. Public Works
 - d. Health
 - e. Others _____
3. Each sheet of the construction documents must bear the signatures, registration number and expiration date of the registered design professional in responsible charge licensed in the State of California.
4. The address of the project and the name/address of the owner are required on the first sheet or title sheet of the construction documents. Include the name/address of the registered design professionals and/or consultants on the construction documents where applicable.
5. _____ set(s) of construction documents will be required during permit issuance. Construction documents must be:
 - a. Quality blue or black line drawings with uniform and light background color.
 - b. Max. 36' x 48" size with min. 1/8" lettering size.
 - c. Sticky back details must produce prints without contrasting shades of background color.
6. Provide the following type of information with each set of construction documents:
 - a. Topography Survey Map
 - b. Grading
 - c. Floor Plans
 - d. Two Elevations
 - e. Construction Sections
 - f. Foundation Plans
 - h. Framing Plans
 - i. Structural Details
 - j. Others _____



7. Show the building area, occupancy group(s), use(s), type of construction(s), number of story(ies), height, type of fire sprinklers system provided, and the number of parking space(s) on the first sheet or title sheet of the construction documents. Include justification and analysis for increase in area, height, and/or story.
 8. Show on site plans the natural and finish grade elevations around the perimeter of the building. Show elevations for all floors and top of roof. Survey map signed by a licensed Surveyor or Civil Engineer may be required by the department.
 9. Remove all plans, details or notes that do not pertain to the project.
- o. I-1 occupancy. 24-hour supervised-residential personal care with > 6 persons
 - p. I-2 occupancy. Nonambulatory/bedridden care facility with > 6 persons, 24-hour child care for more than 6 children 2-1/2 years or less
 - q. I-2.1 occupancy. Ambulatory care facility
 - r. I-4 occupancy. Daycare facility for persons of any age (other than Group E or R-3) for less than 24 hours serving > 6 persons
 - s. M occupancy. Mercantile
 - t. R-1 occupancy. Hotels and motels (transient) with < 30 day duration
 - u. R-2 occupancy. Apartments, condominiums, extended-stay hotels with \geq 30 day duration
 - v. S-1 occupancy. Moderate hazard storage
 - w. S-2 occupancy. Low hazard storage
 - x. U occupancy. Utility and miscellaneous structures
 - y. _____ occupancy.

CHAPTER 3 USE AND OCCUPANCY

C. USE AND OCCUPANCY

1. Specify on floor plans uses of all rooms or areas.
2. The occupancy group specified for one or more areas within the building is incorrect. See plan check annotation on sheet _____.
3. One or more occupancy has been incorrectly categorized. Change occupancy designation as identified below:
 - a. A-1 occupancy. Theaters & assembly spaces for viewing performances
 - b. A-2 occupancy. Restaurants, bars, eating & drinking establishments with \geq 50 occupants
 - c. A-3 occupancy. Churches, halls & recreational assembly or "other assembly"
 - d. A-4 occupancy. Indoor arenas
 - e. A-5 occupancy. Outdoor stadiums
 - f. B occupancy. Business type uses, assembly areas with < 50 occupants, outpatient clinics not classified as Group I-2.1
 - g. E occupancy. Educational uses by more than 6 persons through the 12th grade, daycare for more than 6 children older than 2-1/2 years, daycare for 7 to 100 children 2-1/2 years or less with special egress conditions per CBC 308.5.2
 - h. F-1 occupancy. Moderate hazard factory /manufacturing
 - i. F-2 occupancy. Low hazard factory /manufacturing
 - j. H-1 occupancy. Detonation hazards
 - k. H-2 occupancy. Deflagration hazards
 - l. H-3 occupancy. Combustion hazards
 - m. H-4 occupancy. Health hazards
 - n. H-5 occupancy. Semiconductor HPM hazards
4. Religious educational rooms/auditoriums with less than 100 occupant load which are accessory to places of religious worship shall be classified as Group A-3 occupancies. (CBC 305.1)
5. Provide a note on the plans indicating if any hazardous materials will be stored and/or used within the building, which will exceed the quantities listed in CBC T-307.1(1) and T-307.2(2).

CHAPTER 4 SPECIAL DETAILED REQUIREMENTS

D. SPECIAL DETAILED REQUIREMENTS

1. Covered mall buildings shall comply with CBC 402.
 - a. Occupant load shall be determined based on gross leasable area (GLA) in accordance with the following equation: $OLF = [(0.00007 \times GLA) + 25]$; where $30 \leq OLF \leq 50$
 - b. Include food court occupants in egress calculations. (CBC 402.4.1.1)
 - c. Separation between exit passageway and mechanical rooms, electrical rooms, service areas and service elevators must be a min. of 1-hr. fire barrier with 1-hr. door. (CBC 402.4.6)
 - d. Separation between anchor buildings and covered mall must be a (fire wall) (fire barrier) pursuant to CBC 402.7.3
 - e. Provide smoke control. (CBC 402.9)
2. Atriums shall comply with CBC 404.
 - a. Except for areas that are specifically exempt, the entire building shall be provided with an automatic sprinkler system.



- b. Provide areas adjacent to the atrium with a min. 1-hr. fire barrier separation with 3/4-hour opening protectives, or justify omission of separation.
 - c. Required means of egress from sleeping rooms in Group I occupancies shall not pass through the atrium. (CBC 404.9)
3. Underground buildings shall comply with CBC 405.
- a. The building contains an occupied space (other than a parking garage or other use exempted by CBC 405) that is more than (30') (60') below the lowest level of exit discharge.
 - b. Underground buildings shall be of Type I construction.
 - c. Provide an automatic sprinkler system from the highest level of exit discharge and throughout all level below.
 - d. This project includes an underground building lower than 60' below the lowest level of exit discharge. Provide smoke compartmentation in accordance with CBC 405.4.
 - e. Provide smoke control. (CBC 405.5)
 - f. Provide a manual alarm system with an emergency voice/alarm communication system. (CBC 907.2.19)
 - g. Provide a min. of two exits, including at least one from each smoke compartment. (CBC 405.8.1)
 - h. Provide smokeproof enclosures for egress stairs. (CBC 405.8.2)
 - i. Provide emergency/standby power and standpipes.
4. Motor-vehicle related occupancies shall comply with CBC 406.
- a. Provide a min. 24" high vehicle barrier at all floor-elevation differentials greater than 1-foot. (CBC 406.2.4)
 - b. Vehicle ramps may not serve as exits unless a pedestrian walkway is also provided. Show dedicated area that will serve as the pedestrian walkway that is not part of the vehicle ramp. (CBC 406.2.5)
 - c. Vehicle ramps used for parking shall have a max. slope of 1:15. (CBC 406.2.5)
 - d. Slope all parking surfaces to a drain or the vehicle entrance. (CBC 406.2.6)
 - e. Open parking garages shall be of Type I, II or IV construction. (CBC 406.3.3)
 - f. Motor fuel dispensing and repair garage facilities shall comply with CBC 406.5 and 406.6.
 - g. Fuel dispensing canopies require a min. clear height of 13'-6". (CBC 406.5.2)
 - h. Electric vehicle facilities shall comply with CBC 406.7
5. Group I-2 and I-2.1 medical care facilities shall comply with CBC 407.
- a. A smoke barrier complying with 709.1 is required in accordance with CBC 407.4.
 - b. A smoke tight assembly must be provided for corridors in I-2 occupancies per CBC 407.3.
6. Combustible storage shall comply with CBC 413.
- a. In other than R-3 and U occupancies, attics, under-floor and concealed spaces shall be protected by either an automatic fire sprinkler system within the concealed space or protection on the storage side by 1-hr. fire-resistance rated construction with noncombustible or 1 3/4 -inch thick solid wood self-closing doors. (CBC 413.2)
7. Hazardous materials shall comply with CBC 414.
- a. Provide separate floor plans identifying hazardous material quantities, types and locations prepared by a qualified person in accordance with CBC 414.1.3.
 - b. The percentage of max. allowable quantities of hazardous materials per control area for each floor and the total number of control areas shall comply with CBC T-414.2.2.
8. Group E educational facilities shall comply with CBC 442.
- a. The building contains Group E occupancy and must front directly on a public street or a 20-foot wide exit discharge, with at least one required exit located at such public street or exit discharge area. (CBC 442.1)
 - b. Identify all rooms with an occupant load of 300 or more, and provide sufficient details to demonstrate that such rooms have separate means of egress that are atmospherically separated to prevent concurrent contamination of exits with smoke. (CBC 442.2)
 - c. Indicate whether school grounds will be enclosed by fences and gates. If enclosed, identify a safe dispersal area within such enclosed school ground which has at least 3 sq. ft. per occupant. (CBC 442.3)
 - d. Identify location of any daycare, kindergarten, first or second grade and show that such uses are located on the first floor, unless expressly permitted to be located on a different floor level pursuant to CBC 442.4.
 - e. Indicate whether windows will have any metal grills or bars and comply with CBC 442.5.
9. The _____ (use) (building) (occupancy) shall comply with CBC Section _____.

CHAPTER 5 GENERAL BUILDING HEIGHTS AND AREAS

E. HEIGHTS AND AREAS

1. On site plan, dimension distances from building(s) to all property lines, street center lines, and adjacent existing or proposed structures on the site.
2. On site plan show all interior assumed lot lines, any designated flood plains, open space easements or development restricted areas.
3. Show the size, use, occupancy, and type of construction of all existing buildings on the site.
4. Clearly show the max. height of the building as defined in CBC 502.1
5. Clearly show if the lower level is a basement based on the definitions in CBC 502.1.
6. On title sheet, show justification to exceed the basic allowable floor area listed in CBC T-503.
7. On title sheet, show justification to exceed the number of stories or building height listed in CBC T-503.
8. Provide calculations to justify increase in allowable area
9. When a new building is constructed adjacent to an existing building, show the required wall and opening protection requirements for the existing building will be maintained. CBC 503.1.2, T-508.3.3, T-704.8 and CBC 704.3.
10. Identify "Grade Plane" elevation for this project. Show the grade plane reference datum on all elevation and section drawings.
11. Assumed "Grade Plane" elevation is incorrect. Grade plane is determined as the average elevation of the lowest points around the perimeter of the building within the space described in CBC 502.1. Grade plane is not defined as the average of the highest and lowest points adjacent to the building. Justify the assumed grade plane for this project pursuant to CBC 502.1.
12. For R-2 occupancy apartments and condominiums of Type VA construction, the sprinkler increase for height may not exceed 4-stories or 60'. (CBC 504.2)
13. Provide a note on plans that the automatic sprinkler system must comply with the provisions of CBC 909.3.3.1.1 (NFPA-13) in order to achieve an increase in (height) (area). It shall be the applicant's responsibility to coordinate this requirement with the sprinkler design consultant.
14. When sprinkler increases are applied for an additional 20' in height or for an additional story in accordance with CBC 504.2, sprinklers may not be used for an area increase in CBC 506.3 for Group A, E, H, I, L, Occupancies and high-rises.
15. Building contains one or more of the following Group Occupancies: A, E, H, I, L, or R or is a high-rise building. Pursuant to CBC 506.3, an automatic sprinkler system may be used for either an area increase or a height increase, but not both.
16. Justify the multiple-story increase in the allowable area for the building. The building contains one or more of the following Group occupancies: A, E, H, I, L, or R or is a high-rise building. Therefore, the allowable area for the building may only be doubled, and shall not be tripled. (CBC 506.4)
17. On site plan, clearly delineate any frontage used to justify allowable area increases per CBC 506.2.
18. Justify area frontage increase factor (If). Ratio of W/30 shall be limited to a value of 1.0 unless the building meets the requirements for unlimited area except for the 60' wide yards.
19. Note on plans: "Frontage used for allowable area increases per CBC 506.2 shall be permanently maintained".
20. The area increases per CBC 506.3 shall not apply for:
 - a. Group H-1, 2 or 3 occupancies.
 - b. Where fire rating substitution of CBC T-601, Note e is used.
 - c. Group L occupancies.
21. For buildings equipped with an NFPA 13R or 13D sprinkler system, the area increases per CBC 506.3 do not apply.
22. This building contains Group A-4 occupancy. Unlimited area provisions of CBC 507.3 do not apply.
23. Unless considered a separate story, the floor area of a mezzanine shall be considered a part of the story in which it is located. CBC 505.1

24. Occupancy separation is required in Group B and M when storage area exceed 10% of the floor area, or exceeds 3,000 sq. ft. with sprinklers or exceeds 1,000 sq. ft. without sprinklers. CBC T-508.3.3, Footnote b.
25. Provide fire separation for incidental use area in the _____ in accordance with CBC 508.2 and T-508.2.

F. MIXED OCCUPANCY BUILDINGS

1. Where mixed occupancy buildings contain incidental use areas, the following shall apply:
 - a. Clearly identify on plans whether there are any incidental use areas that are separated from other portions of the building pursuant to CBC T-508.2.
 - b. The protection used for incidental use areas may include automatic fire sprinklers, fire-resistance rated construction, or both. Identify such protection in the incidental use areas on each floor plan.
 - c. When CBC T-508.2 allows incidental uses to be protected by an automatic fire sprinkler system without the construction of a fire-resistance rated wall or floor ceiling assembly, such area shall be separated from the remainder of the building by construction capable of resisting the passage of smoke such as a smoke barrier or smoke partition. (CBC 508.2.2.1)
2. Where mixed occupancy buildings contain nonseparated uses, the following shall apply:
 - a. Clearly identify on plans whether nonseparated uses will be utilized pursuant to CBC 508.3.2.
 - b. The adjoining nonseparated uses must be clearly identified on all floor plans, including the boundary of such areas
 - c. The project must be designed to meet the requirements of the more restrictive occupancy for the following: (Area) (Height) (Egress) (Fire Sprinklers) (Other)
3. Where mixed occupancy buildings contain separated uses, the following shall apply:
 - a. Clearly identify on plans the boundary of each adjoining occupancy that will be separated pursuant to CBC 508.3.3 and T-508.3.3
 - b. Fire-resistance rated walls used to separate adjoining occupancies shall be constructed as fire barriers; fire partitions shall not be allowed. (CBC 508.3.3.4.1)
 - c. Fire-resistance rated floor-ceiling assemblies used to separate adjoining occupancies shall comply with CBC 711. (CBC 508.3.3.4.1)

4. Where mixed occupancy buildings contain accessory areas, the aggregate area of all accessory areas within a single occupancy shall not exceed 10% of the floor area of the primary occupancy. (CBC 508.3.1)
5. For buildings with mixed occupancies, the allowable area per story shall be based on the most restrictive provisions for each occupancy when the mixed occupancies are treated according to CBC 508.3.2 (unseparated). If treated per CBC 508.3.3 (separated) the max. total building area shall be such that the sum of the ratios for each of the actual to allowable are does not exceed 1.

CHAPTER 6 TYPES OF CONSTRUCTION

G. TYPES OF CONSTRUCTION

1. Exterior walls shall have a fire-resistance rating not less than that specified in CBC T-601 and T-602. Provide details of its construction.
2. Structural elements in exterior walls required to be of fire-resistance-rated construction shall have fire-resistance rating equal to or greater than that required for an exterior bearing wall. (CBC T-602)
3. Provide details, notes and specifications for the fire protection of building elements as required for the type of construction. (CBC T-601 and CBC 602)

CHAPTER 7 FIRE-RESISTANCE-RATED CONSTRUCTION

H. EXTERIOR WALLS

1. Projections located where openings are required to be protected shall be non-combustible, heavy timber, or 1-hr. construction. (CBC 704.2)
2. Projections beyond the exterior wall shall not extend beyond (clearly show on elevations/cross section):
 - a. A point one-third the distance from an assumed vertical plane located where protected openings are required due to location on property. (CBC 704.2)
 - b. More than 12" into areas where openings are prohibited. (CBC 704.2)
3. When two or more buildings are on the same property and they are not analyzed to comply as one building, the building shall have an assumed property line between them for determining wall and opening

- protection, and roof cover requirements or treated as a single building per CBC 704.3.
4. When a new building is constructed adjacent to an existing building, an assumed property line shall be places between them such that the existing wall and opening protection requirements for the existing building will be maintained. (CBC 503.1.2, T-508.3.3, T-704.8 and 704.3)
 5. The fire resistance rating of exterior walls shall comply with the provisions of CBC 704.5.
 6. The max. area of exterior wall openings in any story shall not exceed that allowed in CBC T-704.8.
 7. Where both unprotected and protected openings are permitted, the total area is limited to Eq. 7-2. (CBC 704.8, T-704.8)
 8. Parapets shall be provided on exterior walls. (CBC 704.11)
 9. Parapets shall have the same fire-resistance rating as the wall supporting them. The uppermost 18" of the parapet wall facing the roof shall be of noncombustible face materials. (CBC 704.11.1)
 10. Openings in exterior walls required to have protected openings shall have fire protection rating of (3/4) (1-1/2) hour assemblies. (CBC 704.12, T-715.4, T-715.5)
- I. INTERIOR WALLS**
1. Clearly label and identify on plans fire walls, fire barriers, fire partitions, shafts, smoke barriers, and smoke partitions, along with their fire-resistance ratings.
 2. On site plan and floor plans, clearly show location of all fire walls as defined in CBC 705.
 3. Construct a fire wall (sometimes party wall) at property lines or when separating a building into two or more separate areas per CBC 705.1.
 4. Provide details to show that fire wall complies with CBC 705 including but not limited to:
 - a. Fire rating shall be ____-hour per CBC T-705.4
 - b. Fire walls must remain structurally stable in the event of collapse of construction on either side during a fire. Provide a detail to show that joist supported by the fire wall is spliced and not continuous (plywood membrane may be continuous), or provide double fire walls or provide justification for any other method used. 705.2
 5. No openings are allowed in the party wall per 705.1.1 when a wall is constructed on or near a property line.
 6. Where separating areas of buildings for the purpose of sprinkler requirements, provide a 4-hour fire wall per CBC 705.1.2 since your project is subject to SFM amendments.
 7. Fire walls terminating at exterior walls must comply with CBC 705.5.1.
 8. Fire-resistance-rated exterior wall construction shall be maintained through crawl spaces, floor framing, and attic spaces in accordance with CBC 705.6.
 9. Combustible members framed into hollow fire walls or fire walls of hollow units, hollow spaces shall be solidly filled for the full thickness of the wall and for a distance not less than 4" above, below and between the structural members, with noncombustible materials approved for fireblocking. (CBC 705.7)
 10. Fire walls which are not party walls per CBC 715.4 require openings to comply with CBC 705.8.
 11. A complete ____-hour separation is required between Group ____ and Group ____ occupancies. Separation walls shall to be fire barriers complying with CBC 706. Horizontal assemblies shall comply with CBC 711. Openings in the separation shall have ____-hour fire assemblies. (CBC 508.3.3, T-508.3.3, 706, 711, and 715)

12. Fire barriers and horizontal assemblies separating single occupancies into different fire areas shall be ____-hour fire rated per CBC T-706.3.9
13. Areas of each opening in fire barrier are limited 156 sq. ft. Total width is limited to 25% of the wall length in the story under consideration. (CBC 706.7)
14. Fire barrier continuity must be detailed in accordance with 706.5 CBC.
15. Fire barrier at vertical occupancy separations must have continuity and must extend through underfloor area, attic areas, and suspended ceiling areas (706.5)
16. Openings in a fire barrier shall be protected in accordance with CBC 715, limited to a max. aggregate width of 25% and no opening shall exceed 156 sq. ft. (CBC 706.7)
17. A ____-hour fire barrier is required between _____ occupancy and the _____ occupancy. (CBC 508.3.3, T-508.3.3 and 706.3.8)
18. Provide a fire barrier in accordance with CBC 706 for the:
 - a. Shaft enclosure per CBC 707.4.
 - b. Exit enclosure per CBC 1020.1.
 - c. Exit passageway per CBC 1021.1.
 - d. Horizontal exit per CBC 1022.1.
 - e. Atrium per CBC 404.5.
 - f. Incidental use area at the _____ per CBC 508.2 and T-508.2.
 - g. Control areas per CBC 414.2.3.
 - h. Occupancy separation per CBC 508.3.2.
 - i. Fire area separation per CBC 706.3.9.
19. The fire barrier or horizontal assembly, or both, separating a single occupancy into different fire areas shall have a fire resistance rating of not less than that indicated in CBC T-706.3.9.
20. Provide ____-hour fire rated door assemblies in ____-hour fire barrier. (CBC 706.7 and T-715.4)
21. Glazing and openings in fire barriers shall be limited to 25% of the wall area, no larger than 156 sq. ft. with unless tested to match wall rating. (CBC 706.7)
22. All structural elements supporting a fire barrier must have the same fire-resistance ratings as the required occupancy separation. (CBC 706.5)
23. Provide a fire partition in accordance with CBC 708.1 for:
 - a. Walls separating dwelling units.
 - b. Walls separating sleeping units in R-1 hotels, R-2's and I-1's.
 - c. Walls between mall tenant spaces.
 - d. Corridor walls.
 - e. Elevator lobby per CBC 707.14.1.
24. Fire partition continuity must be detailed in accordance with CBC 708.4.
25. Smoke barriers shall have a min. 1-hr. fire-resistance rating. (CBC 709.3)
26. Smoke barriers shall from an effective continuous barrier per the requirements of CBC 709.4.
27. Smoke partitions shall comply with the requirements of CBC 710.
28. Floor and roof assemblies required to have fire-resistance rating shall comply with the requirements of CBC 711.
29. In 1-hr. fire-resistance-rated horizontal assemblies where unusable space occurs above or below the assembly, the membrane on the unusable side of the assembly is not required to be installed. CBC 711.3.3
30. Penetrations of fire-resistance-rated construction must comply with CBC 712.
31. In fire-resistance-rated walls, detail through penetrations and membrane penetrations per CBC 712.3.
32. Penetrations in fire-resistance-rated walls shall comply with CBC 712.3. Through penetrations shall comply with CBC 712.3.1.1 or 712.3.1.2, or as noted below: (CBC 712.3.1)
 - a. Steel, ferrous or copper pipes may penetrate fire-resistance rated walls, provided the opening is protected as follows: (CBC 712.3.1 EX.)
 - i. Item penetrating concrete or masonry walls is a max. 6" nominal diameter and the area of the opening through the wall does not exceed 144 sq. in., concrete, grout or mortar is permitted where it is installed the full thickness of the wall or the thickness required to maintain the fire-resistance rating; or
 - ii. When the annular space is protected with material that meets ASTM E 119.
 - b. Penetrations shall be fire-stopped by a system installed as tested in accordance with ASTM E 814 or UL 1479, and shall have an F rating of not less than the required fire-resistance-rating of the wall penetrated. (CBC 712.3.1.2)

- c. Membrane penetrations of max. 2-hr. fire-resistance rated walls by steel electrical boxes are permitted, provided that each does not exceed 16 sq. in. in area and the total area of such openings does not exceed 100 sq. in. for any 100 sq. ft. of wall area, and the space between the wall membrane and the box does not exceed 1/8". Additionally, outlet boxes on opposite sides of the wall shall be separated by a horizontal distance of not less than 24". (CBC 712.3.2 EX. 1)
 - d. Membrane penetrations by listed electrical boxes of any material are permitted, provided such boxes have been tested for use in fire-resistance-rated assemblies, and the space between the wall membrane and the box does not exceed 1/8" unless listed otherwise. Additionally, outlet boxes on opposite sides of the wall shall be separated by a horizontal distance of not less than 24". (CBC 712.3.2 EX. 2)
 - e. A fire sprinkler shall be permitted to be unprotected provided such space is covered by a metal escutcheon plate. (CBC 712.3.2 EX. 3)
 - f. Where walls are penetrated by other materials or openings larger than those mentioned above, they must be qualified by tests in accordance with CBC 703.2.
33. In fire-resistance-rated horizontal assemblies, detail through penetrations and membrane penetrations per CBC 712.4.
34. Penetrations of fire resistance-rated horizontal assemblies shall comply with CBC 712.4. Through penetrations shall comply with CBC 712.4.1.1.1 or 712.4.1.1.2, or as noted below: (CBC 712.4.1.1)
- a. Steel, ferrous or copper conduits may penetrate a single fire-resistance-rated floor assembly when the annular space is protected with material that meets ASTM E 119. (CBC 712.4.1.1 EX. 1)
 - b. Penetrating items, as noted above, with a max. 6" nominal diameter shall not be limited to the penetration of a single fire-resistance rated floor assembly, provided that the area of the openings does not exceed 144 sq. in. in any 100 sq. ft. of floor area. (CBC 712.4.1.1 EX. 1)
 - c. Penetrations shall be fire-stopped by a system installed as tested in accordance with ASTM E 814 or UL 1479. The system shall have an F rating and T rating of not less than 1-hr. but not less than the required fire-resistance rating of the floor penetrated. (CBC 712.4.1.1.2)
 - d. Membrane penetrations by listed electrical outlet boxes are permitted provided such boxes have been tested for use in fire-resistance-rated assemblies, and the space between the ceiling membrane and the box does not exceed 1/8" unless listed otherwise. (CBC 712.4.1.2 EX. 3)
 - e. A fire sprinkler shall be permitted to be unprotected provided such space is covered by a metal escutcheon plate. (CBC 712.4.1.2 EX. 4)
35. Joints installed in or between fire-resistance-rated walls, floor or floor/ceiling assemblies and roofs or roof/ceiling assemblies shall be protected an approved fire-resistant joint system with a fire-resistance rating not less than that of the assembly in which it is installed. Provide details. (CBC 713.1)
36. Fire-resistance-rated assemblies shall be supported with a structural system having an equivalent fire-resistance-rated protection. (CBC 714.1)
37. Envelope ceilings cannot be used to provide fire protection for columns, girders, trusses, beams, lintels or other structural members supporting more than two floors or one floor and roof, or support a load-bearing wall or a non-load-bearing wall more than two stories high. (CBC 714.2.1)
38. Where columns are required to be fire-resistance rated, the entire column, including its connections, shall be protected. (CBC 714.2.2)
39. Where the fire protective covering of a structural member is subject to impact damage from moving vehicles, the handling of merchandise or other activity, the fire protective covering shall be protected by corner guards or by a substantial jacket of metal or other noncombustible material to a height adequate to provide full protection, but not less than 5' from the finished floor. (CBC 714.4)
40. Openings protectives in firewalls must comply with CBC 715 CBC and T-715.4.
41. Fire door assemblies shall also meet the requirements for a smoke and draft control assembly. (CBC 715.4.3.1)
42. Fire door assemblies in exit enclosures and exit passageways shall have a max. transmitted temperature end point of not more than 450° F (250° C) above ambient at the end of 30 minutes. (CBC 715.4.4)
43. Fire doors and fire-protection rated glazing shall bear labels as required by CBC 715.4.5 and 715.4.6.3.
44. Fire dampers shall have the min. fire protection rating specified in CBC T-716.3.1 for the type of penetration. (CBC 716.3.1)

45. Fire dampers, smoke dampers, combination fire/smoke dampers and ceiling radiation dampers shall be provided as prescribed in CBC 716.5.1 through 716.5.5 and CBC 716.6.
46. Fireblocking shall be installed in combustible concealed locations in accordance with CBC 717.2 in the following locations: (Provide Details)
 - a. In concealed spaces of stud walls and partitions, including furred spaces and parallel rows of studs or staggered studs, as follows:
 - i. Vertically at the ceiling and floor levels.
 - ii. Horizontally at intervals not exceeding 10'.
 - b. At all interconnections between concealed vertical stud wall or partition spaces and concealed horizontal spaces created by an assembly of floor joists or trusses, and between concealed vertical and horizontal spaces such as occur at soffits, drop ceilings, cove ceilings and similar locations. (CBC 717.2.3)
 - c. In concealed spaces between stair stringers at the top and bottom of the run. Enclosed spaces under stairs shall also comply with CBC 1009.5.3.
 - d. Where annular space protection is provided in accordance with CBC 707.2 EX. 6, CBC 712.4.1.2 EX. 1, or CBC 712.4.2, fireblocking shall be installed at openings around vents, pipes, ducts, chimneys and fireplaces with an approved material to resist the free passage of flame and the products of combustion. (CBC 717.2.5)
47. Draftstopping shall be installed in combustible concealed locations in accordance with CBC 717.3 and 717.4, respectively, at the following locations: (Provide Details)
 - a. In floor-ceiling assemblies so that horizontal floor areas not exceed 1,000 sq. ft. (CBC 717.3.3)
 - b. In attics and concealed roof spaces, such that any horizontal area does not exceed 3,000 sq. ft. (CBC 717.4.3)
 - c. Show draft-stop construction on the plans. Draftstopping materials shall not be less than 1/2" gypsum board, 3/8" wood structural panel, 3/8" particleboard, 1" nominal lumber, cement fiberboard, batts or blankets of mineral wool or glass fiber, or other approved materials adequately supported. (CBC 717.3.1)
 - d. Openings in the partitions shall be protected by self-closing doors with automatic latches constructed as required for the partitions. (CBC 717.4.1.1)
48. Draft stop floor ceiling assemblies per CBC 717.3.2 for R occupancies and 717.3.3 for all others.

49. Draft stop attics and mansards per CBC 717.4.

CHAPTER 8 INTERIOR FINISHES

J. INTERIOR FINISHES

1. Where finish materials are applied on walls, ceilings or structural elements required to have a fire-resistance rating or to be of noncombustible construction, they shall comply with the requirements of CBC 803.4.
2. Note on plans or finish schedule: "Wall, floor and ceiling shall not exceed the flame spread classifications in CBC T-803.5".
3. Thermal and acoustical insulation shall comply with CBC 719. (CBC 803.8)
4. Lateral bracing for suspended ceiling must be provided. Where ceiling is not supporting interior partitions, ceiling bracing shall be provided by four No. 12 gauge wires secured to the main runner within 2" of the cross runner intersection and splayed 90° from each other at an angle not exceeding 45° from the plane of the ceiling. A strut (adequate to resist the vertical component from lateral loads) fastened to the main runner shall be extended to and fastened to the structural members of the roof or floor above. These horizontal restraint points shall be placed 12' o.c. in both directions with the first point within 6' of each wall. Attachment of restraint wires to the structure above shall be adequate for the load imposed. Or provide a structural design in conformance with CBC 803.9.11 and 1613.1.
5. Interior floor finish and floor covering materials shall comply with CBC 804.2 through 804.4.1.
6. Combustible materials installed on or embedded in floors of buildings of Type I or II construction shall comply with CBC 805.1.1 through 805.1.3.
7. Decorative materials and trim installed in buildings governed by the SFM shall comply with the provisions of CBC 806.

CHAPTER 9 FIRE PROTECTION SYSTEM

K. FIRE PROTECTION SYSTEM

1. An approved automatic sprinkler system is required throughout the (entire building) (fire area) where the

- (building) (fire area) contains the following: (CBC 903.2)
- a. Has a(n) _____ occupancy; and/or
 - b. Has a fire area over _____ sq. ft.; and/or
 - c. Has over _____ occupant load.
2. Building with floor areas over 1,500 sq. ft. shall be sprinklered where 20 sq. ft. of opening for every 50' of exterior wall length is not provided on at least one side. (CBC 903.2.10)
 3. Provide automatic sprinkler system at top of rubbish and linen chutes and in their terminal room. When extending through 3 or more floors, additional sprinkler heads shall be installed at alternate floors. (CBC 903.2.10.2)
 4. Add a note on plan: "This building must be equipped with an automatic fire extinguishing system complying with (NFPA-13) (NFPA-13R) (NFPA-13D). The sprinkler system shall be approved by _____ prior to installation." (CBC 903.3.1)
 5. Class (I) (II) (III) standpipe (dry) (wet) (combination) systems are required in this building. Show the location of standpipe hose connections on the plans. (CBC 905.3 & 905.4)
 6. A (manual) (automatic) fire alarm system is required as a condition for the _____ occupancy. (CBC 907.2)

CHAPTER 10 MEANS OF EGRESS

L. EXITS

1. Submit an exit plan that labels and clearly shows compliance with all required egress features such as, but not limited to, common path of travel, required number of exits, occupant load, required width, continuity, travel distance, etc. (CBC 1001.1)
2. In a two-story building, two exits or more are required when occupant load exceeds 30 or, common path of egress travel exceeds 75'. (CBC 1019.1, CBC T-1019.2.)
3. The number of exits shall comply with CBC T-1015.1, T-1019.1 and T-1019.2.
4. Rooms with a common path of egress travel exceeding that allowed in CBC 1014.3 shall have two separate and distinct means of egress.
5. When two exits are required from a building or area, they shall be separated by one-half (one-third if

sprinklered throughout) the diagonal dimension of the building or area served. (CBC 1015.2.1)

6. Exit width shall be not less than permitted by CBC 1005. The net dimension (clear width) shall be used in determining exit width.
7. In single-story buildings, two or more exits are required when criteria in CBC T-1015.1, T-1016.1, T-1019.1 or T-1019.2 are exceeded. (CBC 1015, 1016, & 1019)
8. Two exits or more are required when occupant load of a room or space exceeds the criteria in CBC T-1015.1 or T-1016.1. (CBC 1015 & 1016.)
9. Travel distance to reach an exit shall not exceed that allowed in CBC T-1016.1.
10. Every room or space that is an assembly occupancy shall have the occupant load posted in a conspicuous place near the main exit of the room. (CBC 1004.3)

M. CORRIDORS

1. Provide fire/smoke dampers at duct penetrations of 1 hr corridor walls. (CBC 716.5.4.1)
2. Glazed openings into 1-hr. corridors shall be protected per CBC T-715.5. The total area of such openings shall not exceed 25% of the common wall with any room per CBC 715.5.7.2.
3. Corridor walls may terminate at the ceiling, only if the entire ceiling is an element of 1-hr. floor or roof assembly. (CBC 708.4)
4. 1-hr. corridors and any enclosed ceilings within them shall not be used as an integral part of the duct system. (CBC 1017.4)
5. At rooms with exhaust fans adjacent to corridors, show how make up air is provided. No louvers shall be provided. (CBC 1017.4.d & 715.4.3.1)
6. In fully sprinklered office buildings, corridors may lead through enclosed elevators lobbies, provided all areas of the building have access to an exit, without passing through an elevator lobby. (CBC 1017.5 EX. 2)

N. DOORS

1. Two exits or exit access doors of egress shall be provided from boiler, incinerator, or furnace rooms which exceed 500 sq. ft. and any fuel fired equipment

- exceeding 400,000 BTU input capacity. One exit is permitted to be a fixed ladder or alternating tread device. Exit access doorways shall be separated by a horizontal distance equal to one-half the max. horizontal dimension of room. (CBC 1015.3).
2. Each leaf of door in the means of egress shall provide 32" clear opening and a min. height of 6'-8", but in no case shall any swinging door leaf exceed 48". (CBC 1008.1.1)
 3. Provide specifications for the door hardware (i.e., lever type, push-pull, panic, etc) to comply with disabled access requirements. (CBC 1133B.2.5.2)
 4. Doors serving an occupant load of 50 or more or hazardous rooms or areas shall swing in the direction of exit travel CBC 1008.1.2.
 5. All exit doors and gates from an _____ occupancy shall not be provided with a latch or lock, unless it is panic hardware. (CBC 1008.1.9)
 6. Revolving, sliding or overhead doors shall not be used as exit doors. (CBC 1008.1.2)
 7. Show that power operated doors are capable of being manually opened to permit exit travel in the event of a power failure. (CBC 1008.1.3.2)
 8. When additional doors are provided, they shall conform to the provisions for exit doors. (CBC 1008.1)
 9. Landings or floor level at doors shall not be less than 1/2" below the threshold. Raised thresholds and floor level changes greater than 1/4" at doorways shall be beveled with a slope not greater than one unit vertical in two units horizontal. (CBC 1008.1.6)
 10. The bottom 10" of all doors, except automatic and sliding, shall have a smooth, uninterrupted surface. (CBC 1133B.2.6)
 11. Corridor and exit balcony width shall be not less than (72") (44") (36") (24"). (CBC 1017.2)
 12. Doors opening into the path of egress travel shall not reduce the required width to less than one half during the course of swing. When fully open, the door shall not project more than 7" into the required width. (CBC 1005.2)
 13. Dead end corridors shall not exceed 20' (50') in length. (CBC 1017.3)
 14. Provide a complete architectural section of 1-hr. corridor detailing fire-resistance-rated construction of the walls and ceilings. Detail all duct and other penetrations. (CBC 708.4, 1017.1, 715.1, T-715.4 & 716.5.4)
 15. Doors and their frames opening into a 1-hr. corridor shall be labeled 20-minute assemblies with smoke and draft control assemblies with self or automatic closers. (CBC 715.4.3 & 715.4.7)
- O. STAIRWAYS**
1. Stairs shall have a min. width of 44" (36"). (CBC 1009.1)
 2. Stair leading from an area of refuge requires a min. of 48" clear between handrails. (CBC 1007.3)
 3. Provide section and details of interior or exterior stairway showing:
 - a. Max. tread rise of 7" (min. 4") and min. tread run of 11". (CBC 1009.3)
 - b. Min. headroom of 6'-8". (CBC 1009.2)
 - c. Enclosed usable under stairways require 1-hr. construction on enclosed side. (CBC 1009.5.3)
 - d. Provide visual striping per CBC 1133B.4.4.
 4. Door swinging over landing shall not reduce the width by more than 7" when fully open. When serving 50 or more, the door in any position shall not reduce the required width to less than one-half. (CBC 1008.1.5)
 5. Provide a barrier from upper stairs, and stairs leading to the basement. (CBC 1020.1.5)
 6. Stairs shall be enclosed with fire barriers per CBC 1020.1. Enclosure shall conform to the following:
 - a. 2-hr. fire-resistance-rated construction in all buildings 4 or more stories in height and 1-hr. for all other buildings less than 4 stories.
 - b. Only exit doors from habitable space and egress from the enclosure can open into exit enclosures.
 - c. Doors opening into exit enclosures shall be protected per CBC 715.
 - d. Exit enclosures shall include an exit passageway of the same fire-resistance-rated construction as the enclosure leading to the outside of the building, including openings.
 - e. Useable space is not allowed under the stairs. (CBC 1009.5.3)
 - f. Exterior stairs shall be separated from the interior of the building with the same rating required for interior stairs. (CBC 1023.6)

7. Exterior stairs shall be separated from the interior of the building with the same fire-resistance-rated construction required for interior stairs. (CBC 1023.6)
8. In buildings 4 or more stories:
 - a. One stair must extend to the roof. (CBC 1009.11)
 - b. Stairs must have a penthouse or a smoke hatch. (CBC 1009.11.1)
9. Stairs in buildings over 75' (55' due to local ordinance which may apply) in height shall be in a smoke proof enclosure or pressurized stairway per CBC 909.20, 1020.1.7 and 202 high-rise definition.

P. OTHER COMPONENTS

1. Provide connection details of guardrail and/or handrail on open side of landings or stairs adequate to support 50 (20) pounds per lineal foot at a right angle to the top rail. (CBC 1607.7)
2. Design intermediate components of guardrails for a 50 psf lateral load. (CBC 1607.7.1.2)
3. Handrails shall satisfy the following: (CBC 1012)
 - a. Provide continuous handrail.
 - b. Handrail shall be 34" to 38" above the nosing of treads.
 - c. Intermediate balusters shall be spaced 4" o.c. max. on open side(s). (CBC 1013.3)
 - d. The handgrip portion of handrail shall not be less than 1-1/4" nor more than 1-1/2" in cross-sectional dimension. (CBC 1133B.4.2.6)
 - e. The handgrip shall extend 12" beyond the top and 12" plus tread width beyond bottom tread and return the handrail to newel post or wall. (See Title 24 Disabled Access for additional requirements.) (CBC 1133B.4.2.2)
4. Provide 42" high protective guardrail for decks, porches, balconies and raised floors, (more than 30" above grade or floor below) and open side(s) of stair landings. Openings between balusters/rails shall be less than 4". (CBC 1013)
5. Guards shall be provided where the roof hatch opening or mechanical equipment is located within 10' of a roof edge or open side of a walking surface and such edge or open side is located more than 30" above the floor, roof or grade below. The guard shall be constructed so as to prevent the passage of a 21" diameter sphere. (CBC 1013.6)
6. A min. of 2 areas of refuge with one at an elevator must be provided in accordance with Section 1007.1, 1007.2.1, 1007.4 and 1007.6 CBC since your project is four or more stories above grade.
7. Where elevation changes less than 12" occur in the means of egress, sloped surfaces shall be used. (CBC 1003.5)
8. Ramps with a rise greater than 6" shall have handrails on both sides. (CBC 1010.8)
9. Where an egress court serving a building or portion thereof is less than 10' in width, the egress court walls shall have not less than 1-hr. fire-resistance-rated construction for a distance of 10' above the floor of the court. Openings within such walls shall be protected by opening protectives having a fire protection rating of not less than 3/4 hour. (CBC 1024.5.2)
10. Exterior balconies, stairways and ramps shall be located at least 10' from adjacent lot lines and from other buildings on the same lot unless the adjacent building exterior walls and openings are protected in accordance with CBC 704 based on fire separation distance. (CBC 1024.3)
11. Balconies used for egress purposes shall conform to the same requirements as corridors for width, headroom, dead ends and projections. (CBC 1014.5)
12. Exterior egress balconies shall be separated from the interior of the building by walls and opening protection as required by corridors. (CBC 1014.5.1)
13. The means of egress system shall be illuminated with at least one foot candle at the floor level. (CBC 1006.2)
14. Provide a separate source of power for exit sign illumination. (CBC 1011.5.3)
15. Exit signs are required when 2 or more exits are required. Show location of all exit signs. (CBC 1011.1)
16. Show conformance for floor-level exit signs and exit path marking in A, E, I, R-1, R-2 and R-4 occupancies per CBC 1011.6 and 1011.7 as enforced by the State Fire Marshall.
17. Show two sources of power for means of egress. (CBC 1006.3)

CHAPTER 11A & 11B ACCESSIBILITY REGULATIONS

See separate accessibility plan review checklist for Title 24, Part 2, of the California Code of Regulations, Sections 108.2.1.2, 109.1 and 1102A, the state's disabled access and adaptability requirements.

CHAPTER 12 INTERIOR ENVIRONMENT

Q. INTERIOR ROOM, LIGHT AND VENTILATION

1. Provide a door and window schedule. Show type and size of each.
2. Show the following dimensions for each room or area:
 - a. Occupiable spaces, habitable spaces, hallways & corridors shall have a ceiling height of no less than 7'-6". (CBC 1208.2).
 - b. Bathrooms, toilet rooms, kitchens, storage rooms, & laundry rooms shall have a ceiling height of no less than 7'. (CBC 1208.2)
 - c. Kitchen shall have a clear passageway of not less than 3'. (CBC 1208.1)
3. Toilet and bathing room floors shall have a smooth, hard, nonabsorbent surface such as Portland cement, ceramic tile or other approved material that extends upward onto the walls at least 6". (CBC 1210.1)
4. Public toilet rooms shall be provided with a mechanical exhaust system capable of providing a min. 50 CFM per each water closet and urinal and a min. 70 CFM for heavy use application such as theater, school, etc. (CMC T-4-4)
5. Dimension a min. 15" clearance from center of water closet compartment to any side-wall or obstruction nor 30" clearance from center to center to any similar fixture and a min. 24" clear space in front of water closet for bathroom at _____. (CPC 407.6)
6. Walls within 2' of the front and sides of urinals and water closets shall have a smooth, hard, nonabsorbent surface of Portland cement, concrete, ceramic tile or other approved material surface to a height of 4', and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. (CBC 1210.2)
7. Toilet rooms may not open directly to food preparation facilities for service to the public in accordance with CBC 1210.5.
8. All shower compartments, regardless of shape, shall have a min. finished interior area of not less than 1,024 sq. in. and shall be capable of encompassing a 30" circle. Shower doors shall swing out. The min. area and dimensions shall be maintained to a point 70" above the shower drain outlet. (CPC 411.7)
9. Shower compartments and walls above bathtubs with installed shower heads shall be finished with a smooth and nonabsorbent surface to a height not less than 70" above the drain inlet per CBC 1210.3. Use of water-resistant gypsum backing board shall be per CBC 2509.2.
10. Occupied spaces shall be provided with natural ventilation by means of readily controllable exterior openings with an area not less than 4% of the total floor area. Such exterior openings shall open directly to the outdoors or to a yard or court that complies with CBC 1206. Clearly specify on plans how the building is provided with the required ventilation. (CBC 1203.1, 1203.4 and 1203.5)
11. Occupancies and operations involving flammable or combustible hazards or other contaminant sources shall be designed in accordance with CMC. (CBC 1203.5)
12. This plan contains _____ courts. Provide details of the proposed wall construction, opening protection and stair protection. (CBC 202, 1206.3, 1203.4.3 and 1024.5)
13. The width of courts shall meet the following: (CBC 1206.3)
 - a. Not less than 3' in width
 - b. Not less than 6' in width where openings occur on opposite sides
14. Courts shall not be less than 10' in length. (CBC 1206.3)
15. Courts located in buildings more than 2-stories in height shall be shall be increased: (CBC 1206.3)
 - a. 1' in width for each additional story
 - b. 2' in length for each additional story
16. Court access shall be provided at the bottom of courts. (CBC 1206.3.1)
17. Courts more than 2-stories shall be provided with horizontal air intake at the bottom not less than 10 sq. ft. and leading to the exterior of the building. (CBC 1206.3.2)
18. Courts shall be properly graded and drained to an approved disposal system. (CBC 1206.3.3)

CHAPTER 14 EXTERIOR WALLS

R. EXTERIOR WALLS

1. Provide veneer details. Show method of anchorage, size and spacing of anchors. Comply with the applicable requirements in CBC 1405.

CHAPTER 15 ROOF ASSEMBLIES AND ROOFTOP STRUCTURES

S. ROOF

1. The min. roof coverings installed on buildings shall comply with CBC T-1505.1 based on the type of construction of the building. Roof covering shall be Class C rated or better or as required. (CBC 1505.1)
2. Identify on the plans the fire-retardant roof classification, manufacturer's name, and ICC/UL/SFM report number.
3. Provide specifications for roofing material and application.
4. Specify approved weatherproof walking surface material at decks and balconies.
5. Clay and concrete tile attachment shall comply with CBC T-1507.3.7. Notes shall be provided on the plans to show compliance. (CBC 1507.3.7)
6. Roof slope shown on the plans is not adequate for the type of roof covering specified. The min. roof slope shall be provided as follows:
 - a. Min. 2% (0.25:12) for built-up roofs. (CBC 1507.10.1)
 - b. Min. 8% (1:12) for mineral-surfaced roll roofing. (CBC 1507.6.2)
 - c. Min. 17% (2:12) for asphalt shingles. (CBC 1507.2.2)
 - d. Min. 21% (2.5:12) for clay and concrete tiles. (CBC 1507.3.2)
 - e. Min. 25% (3:12) for metal or wood shingles. (CBC 1507.5.2, 1507.8.2)
 - f. Min. 33% (4:12) for slate shingles and wood shakes. (CBC 1507.7.2, 1507.9.2)
7. Show roof slope(s), drain(s) and overflow drain(s) or scupper(s) on the roof plan. Provide a detail of the roof drain and overflow system. Roof drainage system shall comply with the following requirements: (CBC 1503.4, CPC 1108)
 - a. Size the roof drains and overflow drains in accordance with Chapter 11 of the CPC. (CBC 1503.4)
8. The net free ventilating area in enclosed attics and enclosed rafter spaces shall not be less than 1/150 of the area of the space ventilated. Show calculations, size and location on the plans. (CBC 1203.2)
9. An opening not less than 20" x 30" shall be provided to any attic area having a clear height of over 30". Min. clear headroom of 30" in the attic space shall be provided at or above the access opening. (CBC 1209.2)
10. Access to mechanical appliances in under-floor areas, in attic spaces, and on roofs or elevated structures shall be in accordance with the California Mechanical Code. (CBC 1209.3)
11. Provide and detail access to equipment on roof per CMC 904.10.3.
12. Show that the penthouse and/or roof structures satisfy the requirements of CBC 1509. (CBC 1509)

CHAPTER 24 GLASS AND GLAZING

T. GLASS AND GLAZING

1. Each pane of safety glazing installed in hazardous locations shall be identified by a manufacturer's designation specifying who applied the designation, the manufacturer or installer and the safety glazing standard. The following shall be considered specific hazardous locations for the purposed of safety glazing. Glazing in: (CBC 2406)
 - a. Swing doors.
 - b. Fixed and sliding panels of sliding door assemblies and panels in sliding and bi-fold closet door assemblies.

- c. Storm doors.
 - d. Unframed swinging doors.
 - e. Doors and enclosures for hot tubs, whirlpools, saunas, steam rooms, bathtubs, and showers.
 - f. Fixed or operable panels adjacent to a door where the nearest exposed edge of the glazing is within 24" arc of either vertical edge of the door in a closed position and where the bottom exposed edge of the glazing is less than 60" above the walking surface. Read code for exceptions.
 - g. Fixed or operable panel, other than described in items e and f, which meets all of the following conditions (read code for exception with special installation).
 - i. Exposed area of an individual pane greater than 9 sq. ft.
 - ii. Exposed bottom edge less than 18" above the floor.
 - iii. Exposed top edge greater than 36" above the floor.
 - iv. One or more walking surfaces within 36" horizontally of the plane of the glazing.
 - h. Guards and railings regardless of area or height above a walking surface. Included are structural baluster panels and nonstructural in-fill panels.
 - i. Walls and fences enclosing indoor and outdoor swimming pools and spas where all of the following conditions are present:
 - i. The bottom edge of the glazing is less than 60" above a walking surface on the pool or spa side of the glazing.
 - ii. The glazing is within 60" of a swimming pool or spa water's edge.
 - j. Adjacent to stairways, landings and ramps within 36" horizontally of a walking surface; when the exposed surface of the glass is less than 60" above the plane of the adjacent walking surface (read code for exception with special installation).
 - k. Adjacent to stairways within 60" horizontally of the bottom tread of a stairway in any direction when the exposed surface of the glass is less than 60" above the nose of the tread (read code for exception with special installation).
2. For glass handrails and guards, the panels and their support system shall be designed to withstand the loads specified in Chapter 16. A safety factor of four shall be used. The min. nominal thickness of the glass shall be 1/4". Specify approved report number and manufacturer of glass panel guardrail on plans and/or detail. (CBC 2407)
3. Skylights set at an angle of less than 45 degrees from the horizontal plane shall be mounted at least 4" above the plane of the roof on a curb constructed as

required for the frame. Except for R-3 occupancies, skylights without a curb shall be permitted on roofs with a min. slope of 14 degrees (3 units vertical in 12 units horizontal) per CBC 2405.4 and 2610.2. Glass skylights shall comply with CBC 2405. Plastic skylights shall comply with CBC 2610.

CHAPTER 25 GYPSUM BOARD AND PLASTER

U. GYPSUM BOARD AND PLASTER

1. A corrosion resistant weep screed, min. 26 galv. sheet gage, is required below the stucco at the foundation plate line a min. 4" above earth or 2" above paved area with a vertical attachment flange of 3.5". Weep screeds shall be of a type which will allow trapped water to drain to the exterior of the building. Show these dimensions on a foundation detail drawing. (CBC 2512.1.2)
2. Cement, fiber-cement or glass mat gypsum backers in compliance with ASTM C1178, C1288 or C1325 shall be used as a base for wall tile in tub and shower areas and wall and ceiling panels in shower areas. Water-resistance gypsum backing board shall be used as a base for tile in water closet compartment walls when installed in accordance with GA-216 or ASTM C840. Regular gypsum wallboard is permitted under tile or wall panels in other wall and ceiling areas when installed in accordance with GA-216 or ASTM C840. Water-resistant gypsum board shall not be used in the following locations: (CBC 2509.2)
 - a. Over a vapor retarder.
 - b. In areas subject to continuous high humidity, such as saunas, steam rooms or gang shower rooms.
 - c. On ceilings where frame spacing exceeds 12" o.c. for 1/2" thick and more than 16" o.c. for 5/8" thick.
3. Gypsum board shall be permitted to be used as a horizontal diaphragm ceiling as follows: (CBC 2508.5)
 - a. Max. allowable diaphragm proportions shall be 1.5:1 between shear resisting elements.
 - b. Rotation or cantilever shall not be permitted.
 - c. Not allowed at ceiling level to resist lateral forces imposed by masonry or concrete construction.
 - d. The shear values shall be reduced to 90 pounds per foot for expanded metal or woven wire lath and Portland cement plaster and 30 pounds per foot for all other materials. Construction method and spacing shall be per CBC T-2306.4.5. (LARUCP 23-05)
 - e. Limitations of ASCE 7 Section 12.2.1 shall apply.

